Limitation of scope of ETA-20/0989 (CFS-W P Firestop premium wrap) regarding the <u>floor and wall application</u>

Dear Customer,

unfortunately, we need to inform you that the scope of the ETA-20/0989 is limited as follows

- a. plastic pipes
- b. for EI 90 U/U
- c. the construction Group 4 and 6 outer diameter larger than 110 mm

this application can no longer be used described on ETA

- page 24 and 25, 28 and 29 of 57 (point 8.3.4.1 / 8.3.4.2 / 8.3.4.5 / 8.3.4.6) and
- page 39 and 40, 42 and 43 of 57 (point 8.4.5.1 / 8.4.5.2 / 8.4.5.4 / 8.4.5.5).

Gregory Dillen

Gregory Dillen Head of Marketing Business Unit Fire Protection Hilti Corporation

Schaan, 2022-01-05

Martin Althof Head of Quality Business Unit Fire Protection Hilti Corporation



DECLARATION OF PERFORMANCE

according to Annex III of the Regulation (EU) Nr. 305/2011 (Construction Products Regulation)

Hilti Firestop Wrap CFS-W P

No. Hilti CFS-W P

1. Unique identification code of the product-type:

Hilti Firestop Wrap CFS-W P

2. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification:

Fire Stopping and Sealing Product for Penetration Seals, see ETA-20/0989 (17.03.2021)

| Pipe penetrations | Insulated aluminum composite pipes |
|-------------------|------------------------------------|
| | Insulated plastic pipes |
| | Plastic pipes |

3. Name, registered trade name or registered trade mark and contact address as required pursuant to Article 11(5):

Hilti Corporation, Feldkircherstrasse 100, 9494 Schaan, Principality of Liechtenstein

4. System of AVCP:

System 1

5. European Assessment Document:

EAD 350454-00-1104

European Technical Assessment:

ETA-20/0989 (17.03.2021)

Technical Assessment body:

OIB

Notified body:

MPA-Braunschweig, No.0761

6. Declared performance:

| Essential characteristic | Declared performance | Harmonised technical specification / Method of verification |
|-------------------------------------|------------------------------|---|
| Reaction to fire | Class E | EN 13501-1 |
| Resistance to fire | see ETA-20/0989 (17.03.2021) | EN 13501-2 |
| Air permeability | | |
| Water permeability | | |
| Release of dangerous substances | | EAD 350454-00-1104 and EN 16516 |
| Mechanical resistance and stability | | |
| Resistance to impact and | | |
| movement | | |
| Adhesion | | |
| Airborne sound insulation | | |
| Thermal properties | | |
| Durability | Type: Y ₂ | 350454-00-1104 |

The performance of the product identified above is in conformity with the declared performances. This declaration of performance is issued in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above. Signed for and on behalf of the manufacturer by:

Dorothy Wai

Product Manager Business Unit Chemicals Hilti Corporation

Wi Kut

Martin Althof Head of Quality Business Unit Chemicals Hilti Corporation